



Approval of the Trademark Trevira CS®

Zimmer + Rohde GmbH
Zimmersmühlenweg 14-18
61440 Oberursel
Germany

| | |
|--|-----------------|
| Application No.: | 240875.2 |
| Date of issue: | 19.11.2024 |
| Valid until: | 05.11.2029 |
| Article name: | 10777 |
| End use: | Curtains |
| Square weight (g/m²): | 90 |
| According to customer specification | |
| Composition of the raw materials: | Polyester 100% |
| Composition of the fabric: | Trevira CS 100% |

The article 10777 in col. 900 has been tested under the Trevira trademark application no. 240875 and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH
(This document is valid without signature.)