



## Approval of the Trademark Trevira CS flex®

Zimmer + Rohde GmbH  
Zimmersmühlenweg 14-18  
61440 Oberursel  
Germany

<b>Application No.:</b>	230255.1/ 230256.1/ 230257.1
<b>Date of issue:</b>	19.05.2023
<b>Valid until:</b>	11.05.2028
<b>Article name:</b>	10812
<b>End use :</b>	Drapes Curtains
<b>Square weight (g/m<sup>2</sup>):</b> according to customer specification	115
<b>Composition of the raw materials:</b>	97% Polyester / 3% Wool
<b>Composition of the fabric:</b>	97% Trevira CS 3% Wool

The collection "10812" is granted approval for the trademark Trevira CS flex® for interior use.

The approval of the collection is based on the trademark test results of application no.  
230255 Var. 6461 / 230256 Var. 6457 / 230257 Var. 6475

This collection has been tested according to DIN 4102 part 1, 6.2 and thus also meet the requirements for fire class DIN 4102-B1.

This collection has been tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

This collection has been tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

DIN EN ISO 6940/6941: For Trevira CS fabrics no ignition and no rate of flame spread is measured.

Indorama Ventures Fibers Germany GmbH  
(This document is valid without signature.)