



Date of Issue: 8/29/2024 Report Number: 24-002186

Revision Number:2

DITED Date Order Received: 08/20/2024

For the Account of: Zimmer & Rohde Germany Zimmersmuhlenweg 14-18

61440 Oberursel Germany

Client's	Identification:	10841
Olicitio	identinoation.	100-1

CERTIFICATE OF TESTING

TEST PERFORMED: NFPA 701 Standard Methods of Fire Test for Flame Propagation of Textiles and Films 2019 – Test #1

TEST RESULTS

Specimen	Mass Initial (g)	Mass Final (g)	Mass Loss (%)	Drip Burn (s)	Afterflame (s)
1	14.1	11.3	20	0.0	0.0
2	14.1	12.3	13	0.0	0.0
3	14.2	10.8	24	0.0	0.0
4	14.1	10.5	26	0.0	0.0
5	14.3	11.1	22	0.0	0.0
6	14.1	12.2	13	0.0	0.0
7	14.2	10.5	26	0.0	0.0
8	14.1	10.7	24	0.0	0.0
9	14.3	11.1	22	0.0	0.0
10	14.2	11.0	23	0.0	0.0
Average	14.2	11.2	21	0.0	0.0

Approximate weight (oz./sq.	yd) : 7.0	Standard Deviation: 4.7	Average + 3 SD: 35.1		
Product Configuration:	⊠ Single Layer	☐ Multi Layer			
Conditioning: Oven at 220° Intended End-use (if known & other than drapery):		or minimum 30 minutes apery	☐ 70 ±2°F & 65 ±2%RH for minimum 24 hours		
1. Where fragments of seconds per specing seconds per specing. 2. Where the average second s	or residues of specimens the men for the sample of 10 specimens the weight loss of the 10 specimens will be listed as a failure enside on the demonstrate pessing this test and shall be the the above Results and A	pecimens, the material shall be r cimens in a sample is greater tha e if it exceeds mean + 3 SD	mber continue to burn for more than an average of 2 recorded as failing. (Flaming Drip) an 40 percent, the material shall be recorded as failing. There of the conditions indicated above, the material shall		
SERTIFICATION I certify that specified by the standard star		otained after testing specimen in	accordance with the procedures and equipment		
Authorized Signature			Date Order Completed: 08/27/2024		

553 76th Street, Byron Center, MI 49315

P: 616-559-6123 E: testlab@applied-lab.com

Page 1 of 1