



## Approval of the Trademark Trevira CS flex®

Zimmer & Rohde  
Zimmersmühlenweg  
61440 Oberursel  
Germany

**Application No.:** 230847.3 / 230848.3 / 230849.3  
**Date of issue:** 03.06.2024  
**Valid until:** 01.12.2028

**Article name:** 1290  
**End use:** Drapes  
**Square weight (g/m<sup>2</sup>):** 172  
**according to customer specification**  
**Composition of the raw materials:** 100% Polyester  
**Composition of the fabric:** 96% Trevira CS  
4% Tape Yarn

The collection "1290" is granted approval for the trademark Trevira CS flex® for interior use.

The approval of the collection is based on the trademark test results of application no. 230847 col A01 / 230848 col A98 / 230849 col A15.

This collection has been tested according to DIN 4102 part 1, 6.2 and thus also meet the requirements for fire class DIN 4102-B1.

This collection has been tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

This collection has been tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

Indorama Ventures Fibers Germany GmbH  
(This document is valid without signature.)